



ADDENDUM No. 3	
ITB No.	20-025
ITB TITLE:	Provision and Installation of Strainpress & Associated Goods and Services
ISSUE DATE:	March 13, 2020

To all potential bidders:

This Addendum is being issued to amend and or clarify certain information contained in the above named ITB. All information contained herein is binding on all Bidders who respond to this ITB. The following are changes and or modifications:

1. CHANGE ALL REFERENCES TO THE DATE AND TIME FOR RECEIPT OF BIDS TO READ:

3:00 P.M., April 14, 2020

2. ADD THE FOLLOWING PARAGRAPH UNDER SECTION D, IMMEDIATELY FOLLOWING PARAGRAPH 19:

20. Miscellaneous Responsibilities of Contractor

- a. Promptly, after being awarded the Contract, the Contractor shall prepare and submit to the Contract Manager the schedule for the work covered under this Contract. The schedule shall not exceed the time limits provided in the Contract Documents, and shall be revised at appropriate intervals as required by the conditions of the work and project. shall be related to the entire Project to the extent required by the Contract Documents, and shall provide for expeditious and practicable execution of the work.
- b. The Contractor shall submit for review and approval necessary shop drawings, product data, illustrations, performance charts, instructions, brochures, diagrams and other information necessary for the equipment being installed.
- c. The Contractor shall perform no portion of the Work requiring submittal and review of Shop Drawings, Product Data, Samples or similar submittals until the respective submittal has been reviewed and approved or other appropriate action taken by AlexRenew. Such Work shall be in accordance with approved submittals.
- d. The Contractor shall be responsible for cutting, fitting or patching required to complete the Work or to make its parts fit together properly.
- e. The Contractor shall keep the premises and surrounding area free from accumulation of waste materials or rubbish caused by operations under the Contract. At completion of the work the Contractor shall remove from and about the Project waste materials, rubbish, the Contractor's tools, construction equipment, machinery, and surplus materials. If the Contractor fails to clean up as provided in the Contract Documents, AlexRenew may do so and the cost thereof shall be charged to the Contractor.

- f. The Contractor shall submit a pre-installation (taken immediately prior to commencement of installation activities) and post-installation (when all installation work is completed) photographs of the jobsite with the final invoice for the payment of the installation of equipment.

3. ADD THE FOLLOWING PARAGRAPH UNDER SECTION D, IMMEDIATELY FOLLOWING PARAGRAPH 20:

20. Omissions

It is the intent of this solicitation to describe complete provision and installation, rebuilt and repair services for Strainpress, however, it shall be the Contractor responsibility to employ such means, methods, expertise and superintendence to furnish and install new equipment, provide necessary rebuilt and repair services in accordance with the OEM profile of aforementioned equipment. Any services that have been omitted from this specification which are reasonably inferred for the complete installation, rebuilt and repair and service of the strainpresses shall be considered a requirement although not directly described in this specification.

- 4. REPLACE ATTACHMENT A WITH THE ATTACHED REVISED ATTACHMENT A.**
- 5. ATTACHED ARE ANSWERS TO THE QUESTIONS RECEIVED.**
- 6. ATTACHED IS THE PREBID MEETING SIGN IN SHEET.**

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

Acknowledgement

Name of the Firm:
Signature/Title:
Date:

A. Provision and installation of Strainpress and Overhaul Services

#	EQUIPMENT	QTY	UNIT PRICE		
1	Strainpress®290 manufactured by Huber Technology, including ancillary equipment such as compressor for pneumatic retention cone (min. 2HP, 15 GAL., Tank), support legs, and pressure monitor.	1	\$		
2	Freight and shipment	1	\$		
3	Huber Standard Control Panel: <ul style="list-style-type: none"> • Enclosure, NEMA 4x, 304 Stainless Steel • Motor Starter, IEC Non-Reversing, w/Branch Circuit Protection {5 HP max, 3/60/480 VAC} • PLC, AB Micrologix 1400 • HMI, AB Panel View Plus C400 • UL Label 	1	\$		
4	Installation, Setup, troubleshooting, user training and manuals	1	\$		
5	COMPLETE OVERHAUL SERVICES FOR Strainpress®290 (includes all parts, labor, tools, consumables and all things necessary – i.e. turnkey approach)	1	\$		
6	COMPLETE OVERHAUL SERVICES FOR Strainpress® SC-4 includes all parts, labor, tools, consumables and all things necessary – i.e. turnkey approach)	1	\$		
SUBTOTAL:			\$		
CORRECTIVE MAINTENANCE	EST. # OF HOURS	REGULAR HOURLY RATES	EXTENDED REGULAR HOURLY RATES	EMERGENCY RATES	EXTENDED EMERGENCY RATES
Fully burden Hourly Rate for on-site repairs services	20	\$	\$	\$	\$
SUBTOTAL (SUM OF EXTENDED HOURLY RATES):		\$			

TOTAL BID AMOUNT (SUM OF ALL SUBTOTALS)	\$
WRITTEN IN WORDS	

Timeline for provision of submittals	DAYS FOLLOWING ISSUANCE OF NTP
Timeline for equipment delivery	DAYS FOLLOWING APPROVAL OF SUBMITTALS
Total number of days for installation of Strainpress®290 (total number of days to have a fully-functioning equipment)	DAYS

B. SINGLE RATE DISCOUNT FOR PARTS AND MATERIAL

For those items not specifically listed and priced above that may be provided within the defined scope of this agreement bidders shall submit Master Price List (MPL) documents, A USB

identifying all other items offered pursuant to this agreement to include Description and catalog price

Discount Rate for items on MPL	%
--------------------------------	---

DELIVERY TIME FOR STOCKED ITEMS	AFTER RECEIPT OF ORDER		
DELIVERY TIME FOR STOCKED ITEMS	AFTER RECEIPT OF ORDER		
CONTACT PERSON FOR SCHEDULING OF WORK :	NAME	TELEPHONE	EMAIL ADDRESS
EMERGENCY CONTACT: (THE PHONE MUST BE ANSWERED BY A LIVE PERSON 24 HOURS/7 DAYS A WEEK)			
IS YOUR FIRM AN AUTHORIZED DEALER AND OR REPAIR FACILITY FOR HUBER TECHNOLOGY?	YES	NO	
DID YOU INCLUDE THAT PROOF WITH YOUR BID?			
DID YOU PROVIDE A MINIMUM OF TWO (2) REFERENCES TO ESTABLISH YOUR EXPERIENCE WORKING WITH HUBER TECHNOLOGY?	YES	NO	
DOES YOUR FIRM HAVE A REPAIR FACILITY WITHIN FIVE HUNDRED MILE RADIUS OF 500 EISENHOWER AVENUE, ALEXANDRIA, VA 22314.	YES	NO	
	ADDRESS OF THE FACILITY:		
IS THIS FACILITY FULLY EQUIPPED WITH NECESSARY PERSONNEL, EQUIPMENT, PARTS, TOOLS AND ALL THINGS NECESSARY FOR THE PERFORMANCE OF MAINTENANCE, REPAIR/REBUILT AND OR REPLACEMENT OF COVERED EQUIPMENT.	YES	NO	
DO YOU HAVE STAFF TRAINED IN CONFINED ENTRY PERMIT REQUIREMENTS?	YES	NO	
IN A SEPARATE SHEET PROVIDE A LIST OF EMPLOYEES TO BE ASSIGNED TO WORK UNDER THIS CONTRACT, INCLUDING THEIR NAME, TITLE, PROFESSIONAL EXPERIENCE AND CERTIFICATIONS, AND AREAS OF EXPERTISE AS RELATED TO THE SERVICES THAT WILL BE PROVIDED			
ATTACH A COPY OF YOUR FIRM'S SAFETY POLICIES			
ATTACH A COPY OF YOUR FIRM'S QUALITY CONTROL/QUALITY ASSURANCE PROCEDURES			
ATTACH PRICE LIST FOR PARTS (REFER TO ACCOMPANYING EXCEL SPREADSHEET) -			

The undersigned swears or affirms under the penalty of perjury and upon personal knowledge that the contents of Bid entered and received are true and correct and Bidder has exercised all the necessary due diligence to submit a balanced bid.

The undersigned swears or affirms under the penalty of perjury that the Bidder, its agents, servants and/or employees, to the best of his/her knowledge and belief, have not in any way colluded with

anyone for and on behalf of the Bidder an unfair advantage over others, nor have they colluded with anyone for and on behalf of the Bidder, or themselves, to gain any favoritism in the award of any contract resulting from this bids.

NAME OF AND TITLE BIDDER'S REPRESENTATIVE

SIGNATURE OF BIDDER'S REPRESENTATIVE

INTENTIONALLY LEFT BLANK-

Answers to the Questions Received

#	Question	Answer
1	For the controls Huber would like to provide a VFD. This would not require anything additional from the MCC, or leads to Strainpress, this is all contained in our control panel design. If this is not acceptable, we can accommodate the older style asynchronous motors with a special flange on the Strainpress design which was our initial intention. Please review and let us know your preference.	This substitution will be review post contract award as part of submittal review and approval process.
2	We would require the distance for the location of the certified repair shop to be 400 miles	Refer to attached Revised Attachment A
3	Please consider modification of the bid form on lines 7 and 8 to include a clearer definition of what you would require, potentially a complete rebuild scope on a per each basis not a per year basis. Please consider adding bid items for annual basic service for each press if you make the change on bid items 7&8 above	Refer to attached Revised Attachment A
4	Please clarify the sums you wish added into the total bid, specifically the regular and Emergency hourly rates	Refer to attached Revised Attachment A