

October 15, 2025

IPQ-26-005: Low Pressure Steam System Improvements Addendum No. 1

Respondents shall acknowledge receipt of this Addendum when submitting the bid using page A-5 of Attachment A: Prequalification Application. Failure to do so may result in the rejection of the Bid.

This Addendum consists of the following:

- One (1) page of text
- Responses to Respondent's questions.
- Section 4.4.B.2.c is being revised as follows:
Contractor mechanics shall be certified and licensed by ASME 31.3 (process piping) certification, ~~hold a National Board of Boiler and Pressure Vessels "R" stamp for repairs and alterations and be licensed as inspectors by the Commonwealth of Virginia per Virginia Code Section § 40.1 et seq.~~ All licensures and registrations must be effective as of the date of receipt of the IPQ.

Responses to Respondent's Questions

Q1: Ref: Section 4.4.B.2.c "Evaluation Criteria"

This project involves low pressure steam system work. The requirements in the above paragraph are overly restrictive and non-applicable to this type of work. These requirements will severely limit the competition on the project. We request that this paragraph be deleted.

A1: Section 4.4.B.2.c will now read as follows: Contractor mechanics shall be certified and licensed by ASME 31.3 (process piping) certification. All licensures and registrations must be effective as of the date of receipt of the IPQ.

End of Addendum 1

Applicant's Acknowledgement of Addendum: _____
Signature of Authorized Representative