

September 15, 2026

ITB 27-001: Switchgears Addendum No. 2

Bidders shall acknowledge receipt of this Addendum on the Bid Form in Attachment B of the Invitation to Bid (ITB) with submittal of the Bid. Failure to do so may result in the rejection of the Bid.

Addendum No. 2 to ITB-27-001 consists of the following:

- One (1) page of text, including Responses to Respondent Questions.
- Copies of last test reports from the latest annual maintenance.
 - Attachment A – 2025 Maintenance Report
 - Attachment B – Building F Report

Response to Respondent's Questions

Q1: Can you provide clarification testing scope for Triennial Testing?

A1: Triennial testing shall consist of comprehensive electrical maintenance testing beyond routine annual preventive maintenance activities and shall include verification of protective devices, injection testing, insulation testing, grounding system testing, contact resistance testing, and other applicable diagnostic testing identified in the Contract Documents. The Contractor shall document all findings and compare field conditions against approved settings and equipment records. Previously completed testing may be considered by AlexRenew where documentation demonstrates an equivalent or greater scope.

Q2: The specification for Annual Testing (2.4) also notes both primary and secondary injection testing on breakers however that is typically only done on the Triennial Maintenance cycles. Can you confirm if this is annually or Triennial?

A2: Secondary injection testing shall be performed annually and primary injection testing to be performed during the triennial maintenance cycle. See Pricing Sheet revised by Addendum No. 1 which separated the price for primary injection testing in years 1 and 3.

Q3: Please provide the most recent inspection, maintenance, primary-injection, secondary [1] injection, relay-testing, transformer-fluid-analysis, and infrared-inspection reports for the listed equipment. Historical results are necessary to establish existing conditions and perform the required trend comparisons.

A3: Please see Attachments A and B that accompany this Addendum.

End of Addendum No. 2